



Test report No:

NIE: 2040137R-A332251010

Test Report

LoRa Alliance End Device Certification Requirements

Identification of item tested	Wireless Communication Module
Trademark.....	YOKOGAWA
Model or type reference.....	XS110A
Final HW version.....	S2.01
Final FW version	R1.03.05
Final SW version.....	N/A
Features.....	LoRa Alliance End Device Certification Requirements for US/Canada 915MHz ISM Band Devices
Manufacturer	Yokogawa Electric Corporation 2-9-32 Nakacho, Musashino-shi, Tokyo 180-8750, Japan
Test method requested.....	LoRa Alliance Certification
Standard.....	LoRa Alliance End Device Certification Requirements for US/Canada 915MHz ISM Band Devices Ver.1.5
Test According LoRaWAN™ Spec	V1.0.2
Supported optional features.....	YES
Test procedure(s)	TERD-WTS-TP-02 – LORA_TSSTP_PART_1_v1.0
Summary	IN COMPLIANCE
Approved by (name / position & signature)	Jimmy Chang Project Manager
Date of issue	2020-06-05
Report template No	FLO001_01

Index

Competences and guarantees	3
General conditions.....	3
Uncertainty	3
Usage of samples.....	3
Identification of the client.....	4
Testing period	4
Environmental conditions	4
Remarks and comments.....	4
Revision History.....	4
Means of testing identification	5
Test setup.....	5
Appendix A – Test result	6
Appendix B – ICS	7
Appendix C – IXIT.....	8
Appendix D – General Parameters	9

Competences and guarantees

DEKRA Testing and Certification, Co., Ltd. is a testing laboratory competent to carry out the tests described in this report.

In order to assure the traceability to other national and international laboratories, DEKRA Testing and Certification, Co., Ltd. has a calibration and maintenance program for its measurement equipment.

DEKRA Testing and Certification, Co., Ltd. guarantees the reliability of the data presented in this report, which is the result of the measurements and the tests performed to the item under test on the date and under the conditions stated on the report and, it is based on the knowledge and technical facilities available at DEKRA Testing and Certification, Co., Ltd. at the time of performance of the test.

DEKRA Testing and Certification, Co., Ltd. is liable to the client for the maintenance of the confidentiality of all information related to the item under test and the results of the test.

The results presented in this Test Report apply only to the particular item under test established in this document.

IMPORTANT: No parts of this report may be reproduced or quoted out of context, in any form or by any means, except in full, without the previous written permission of DEKRA Testing and Certification, Co., Ltd.

General conditions

1. This report is only referred to the item that has undergone the test.
2. This report does not constitute or imply on its own an approval of the product by the Certification Bodies or competent Authorities.
3. This document is only valid if complete; no partial reproduction can be made without previous written permission of DEKRA Testing and Certification, Co., Ltd.
4. This test report cannot be used partially or in full for publicity and/or promotional purposes without previous written permission of DEKRA Testing and Certification, Co., Ltd. and the Accreditation Bodies.

Uncertainty

N/A

Usage of samples

Samples undergoing test have been selected by: Yokogawa Electric Corporation

DUT Label ID	PSR-1670723
Model or type reference	XS110A
Serial number	91VC27509
HW version	S2.01
SW version	N/A
FW version	R1.03.05
Description of test sample	Yokogawa XS110A is an Industrial IoT wireless communication module that is used with various measurement modules provided from Yokogawa. These sensors have environmental resistance features to support heavy-duty use. This module contains a battery and it can be a power supply for a measurement module. Yokogawa is offering a temperature sensor and a pressure sensor as measurement module.
Date of reception	2020-05-18

Identification of the client

Company name	Yokogawa Electric Corporation
Address	2-9-32 Nakacho, Musashino-shi, Tokyo 180-8750, Japan

Testing period

Start Date	2020-05-19
Finish Date	2020-05-27

The tests have been performed at DEKRA Testing and Certification, Co., Ltd. (Taiwan)

Environmental conditions

The testing has been performed within the following limits:

Temperature	Min. = 15 °C Max. = 35 °C
Relative humidity	Min. = 20 % Max. = 80 %

Remarks and comments

Test Report Creator	Gavin Yang gavin.yang@dekra.com
Test Engineer	Gavin Yang gavin.yang@dekra.com

Revision History

Revision	Modification Date	Description
01	NA	Initial Report


Means of testing identification

Following equipment was used to perform the testing:

US915 SETUP			
Test System	CN. 556	TACS4 LPWAN Testing, Approvals & Certification System	
Hardware:	Control No.	Equipment	Serial No.
	0584	LoRa 64Ch Gateway TEKTELIC - MACO2LUS915	T0004537
Software:	0559	TACS4 LORA GUI v1.14.0 TACS4 LORA Reporting Module v1.6.0	
	0560	TACS4 LORA Technology Package v5.17.0_R1	

Test setup

The configuration used for Test Cases in nominal temperature conditions was the following one:



Appendix A – Test result

Test campaign report

The abbreviations used in the header row of the test campaign report tables are:

- Test Case ID: Test case identifier, as it can be found on the referred standard.
- Sample: Sample details.
- Description: Test case description, as it can be found on the referred standard.
- Date: Date of the beginning of the execution.
- Conformance: YES/NO. If the test case has been executed in accordance to the standard.
- Verdict: Records the verdict assigned to each Test case run to completion. Following verdicts are possible:
 - PASS:** If the Test case passed.
 - FAIL:** If the Test case failed.
 - INCONC:** Inconclusive. The test case did not reach a PASS or FAIL verdict.
 - NA:** Not applicable.
 - NM:** Not measured.
- Observations: Provides a reference to additional information relevant to the test (when required).

Test Case ID	Description	Verdict	Date	Observations
TP_A_US915_MAC_BV_000	Test Mode Activation	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_001	Over The Air Activation	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_002	Test Application functionality	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_003	AES Encryption and Message Integrity	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_004	Downlink Error Rate	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_005	Downlink Window Timing	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_006A	Frame Sequence Number	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_006B	Downlink Sequence Number Roller	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_007	DevstatusReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_008A	Mac Commands	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_008B	Mac Commands in App-Payload & Fopts	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_009	NewChannelReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_010	Confirm Packets	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_011	RXParamSetupReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_012	RX1 Receive Window Test	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_013	RX2 Receive Window Test	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_014	RX TimingSetupReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_015A	LinkADRReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_015B	LinkADRReq Mac Command	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_016	RX Oversized Payload	Pass	2020-05-27	OTAA
TP_A_US915_MAC_BV_017	Maximum Allowed Payload	Pass	2020-05-27	OTAA

Appendix B – ICS

Item	Name	Value
1	DUT works in USA 915MHz ISM Band	True
2	DUT implements LoRaWAN v1.0.1 certification requirements	False
3	DUT implements LoRaWAN v1.0.2rB certification requirements	True
4	DUT is a Class A Device (All End Device)	True
5	DUT is a Class B Device (Beacon Mode)	False
6	DUT is a Class C Device (Continuously Listening)	False
7	DUT supports Adaptive Data Rate (ADR) feature	True
8	DUT supports LinkADRReq block	True
9	DUT supports Over-The-Air Activation (OTAA) mechanism	True
10	DUT needs a reset after deactivating Test Mode	True
11	DUT supports Trigger Join Request command in Test Mode	True

Appendix C – IXIT

Item	Name	Value
1	End-Device Address (DvAddr)	N/A
2	Application Session Key (AppSKey)	N/A
3	Network Session Key (NwkSKey)	N/A
4	Application Identifier (AppEUI)	0000000000000001
5	Maximum Transmission Power	7 dBm
6	Minumum Transmission Power	7 dBm
7	Application Key (AppKey)	00000000000000000000000000000001
11	Device Identifier (DevEUI)	000064FFFEA96837

Appendix D – General Parameters

Item	Name	Value
GW	Default TX Antenna	0
	Gateway IP Address	192.168.32.3
	Gateway Model	Tektelic
	Default TX Power	14 dBm
	Gateway Socket Port	1780
TM – US915	US915 Join_Accept_Delay1	5.0 s
	US915 Join_Accept_Delay2	6.0 s
	US915 Receive_Delay1	1.0 s
	US915 Receive_Delay2	2.0 s
	US915 RX2 Receive Window DR	SF12BW500
	US915 RX2 Receive Window Frequency	923.3 MHz
	General Timer	90 s