

Test Report on

The Schneider Electric PrismaSeT Wireless Panel Server End Device

Test Report Reference: MDE_LCIE_2011#Schneider_LoRa01

Date: 2021-03-04

Test Laboratory:

7layers GmbH
Borsigstraße 11
40880 Ratingen
Germany

Note:

The following test results relate only to the devices specified in this document. This report shall not be reproduced in parts without the written approval of the test laboratory.

7layers GmbH
Borsigstraße 11
40880 Ratingen, Germany
T +49 (0) 2102 749 0
F +49 (0) 2102 749 350
www.7layers.com

Geschäftsführer /
Managing Directors:
Frank Spiller
Bernhard Retka
Alexandre Norré-Oudard

Registergericht registered in:
Düsseldorf, HRB 75554
USt-IdNr VAT No.:
DE203159652
TAX No. 147/5869/0385
A Bureau Veritas Group Company

Table of Contents

1	Administrative Data	3
1.1	Project Information	3
1.2	Applicant Information	3
1.3	Test Laboratory Information	4
1.4	Signature of the Testing Responsible	4
1.5	Signature of the Accreditation Responsible(s)	4
2	Test Object Data	5
2.1	Object Under Test (OUT) Description(s)	5
2.2	Sample Description(s)	6
3	Results	7
3.1	General	7
3.2	Applicable Test Specification(s)	7
3.3	Result Statistics	7
3.4	Result Summary	8
4	Test Equipment Details	11
4.1	List of Test Equipment	11
5	Annex	12
5.1	Object Under Test (OUT) Features	12
5.2	Sample DE1247001aa01 Extra Information Parameters	12
5.3	Additional Documentation for Samples	13

1 Administrative Data

1.1 Project Information

Project Name: MDE_LCIE_2011
Responsible for Testing and Report: Mohamed El-Fikri
Date of Report: 2021-02-17
Testing Time Frame: 2021-02-10 - 2021-02-15

1.2 Applicant Information

Company Name: Schneider Electric
Address: 31 avenue Pierre-Mendes France
Eybens - F-38050 Grenoble cedex 9
France
Contact Person: Marc Burger
Phone: +33631627232
Email: Marc.Burger@se.com

1.3 Test Laboratory Information

The following list shows all Locations and Test Resources involved in the generation of test results:

7layers DE, Ratingen, Germany

Company Name	7layers GmbH
Address	Borsigstr. 11 40880 Ratingen NRW Germany
Contact	Michael Albert
Phone	+49 2102 749 201
Email	Michael.Albert@7layers.com

List of Test Resources

ID	Name	Responsible	Accreditation Info
1	LCTT LoRa Compliance Test Tool	Mohamed El-Fikri	

1.4 Signature of the Testing Responsible



(Responsible for Testing and Report)
Mohamed El-Fikri

1.5 Signature of the Accreditation Responsible(s)



(Responsible Accreditation Scope)
Constantine Nfor

2 Test Object Data

2.1 Object Under Test (OUT) Description(s)

The following section lists all Objects Under Test (OUTs) involved during testing.

Object Under Test: PrismaSeT Wireless Panel Server MODULE

Description: The PrismaSeT Wireless Panel Server is a LoRaWAN based Sensor for Voltage Loss Alarm

Type / Model: PrismaSeT Wireless Panel

Manufacturer:

Company Name: Schneider Electric

Address: 31 avenue Pierre-Mendes France
Eybens - F-38050 Grenoble cedex 9
France

Contact Person: Nicolas RIOU

Phone: +33631627232

Email: nicolas.riou@se.com

Address: 31 avenue Pierre-Mendes France
Eybens - F-38050 Grenoble cedex 9
France

For further details see Annex.

2.2 Sample Description(s)

Sample Name: DE1247001aa01

Object Under Test:	PrismaSeT Wireless Panel Server
Description:	The PrismaSeT Wireless Panel Server is a LoRaWAN based Sensor for Voltage Loss Alarm
Serial Number:	0080F4FFFEC8FFCF
Hardware Version:	V1.0
Firmware Version:	V1.2.1
Code:	aa01

For further details see Annex.

3 Results

3.1 General

Documentation of tested devices: Available at the test laboratory.

Interpretation of the test results: The results of the inspection are described on the following pages, where 'Conformity' or 'Passed' means that the certification criteria were verified and that the tested device is conform to the applied standard.

In cases where 'Declaration' is stated, the required documents are available in the manufacturer's product documentation.

In cases where 'not applicable' is stated, the test case requirements are not relevant to the specific equipment implementation.

- Notes:**
1. This report contains the abbreviated information content pertaining to services rendered. Supporting documentation not included herein is maintained and available at the test laboratory.
 2. All tests are performed under environmental conditions within the requirements of the specifications. Environmental condition records are available at the test laboratory.

3.2 Applicable Test Specification(s)

Test Specification:	LoRa End Device Certification EU v1.6
Date / Version:	March, 2020 / v1.6
Description:	LoRa Alliance End Device Certification Requirements for EU 863-870 MHz ISM Band devices, v1.6 (LoRaWAN™ core spec. 1.0.2 & LoRaWAN™ Regional Parameters Version 1.0.2rB)

3.3 Result Statistics

Test Specification	Total	Result Verdict			Pass Ratio
		Pass	Fail	Declaration	
LoRa End Device Certification EU v1.6	24	24	0	0	100.00 %

Note: Pass, Declaration, Fail and Inconclusive results are regarded for the Pass Ratio calculation. Pass and Declaration are summarized as Pass results. Fail and Inconclusive are summarized as Fail results. All are summarized as Total count (Pass + Declaration + Fail + Inconclusive). The Pass Ratio is calculated by the number of Pass results divided by the number of Total results. All other results like Error or Not Tested are not regarded for the calculation.

3.4 Result Summary

Test Case ID	Sample	Date	Verdict	Comments
TP_A_EU868_ED_MAC_BV_000 / "Device Activation (OTAA)"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_001_A / "Over the air activation"	DE1247001aa01	2021-02-12	PASS	
TP_A_EU868_ED_MAC_BV_001_B / "Activation By Personalization"	DE1247001aa01	-	N. A	Not applicable
TP_A_EU868_ED_MAC_BV_002 / "Test application functionality"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_003 / "AES encryption and message integrity"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_004 / "Downlink error rate"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_005 / "Downlink window timing"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_006 / "Frame sequence number"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_007 / "DevStatusReq MAC command"	DE1247001aa01	2021-02-09	PASS	

Test Case ID	Sample	Date	Verdict	Comments
TP_A_EU868_ED_MAC_BV_008 / "MAC commands"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_009 / "NewChannelReq MAC command"	DE1247001aa01	2021-02-13	PASS	Tested with following 16-different frequencies in MHz: 865.100; 865.300; 865.500; 865.700; 865.900; 867.900; 867.700; 867.500; 867.300; 867.100; 866.500; 866.300; 866.100; 868.100; 868.300; 868.500 (see also attached Logs)
TP_A_EU868_ED_MAC_BV_010 / "DIChannelReq MAC command"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_011 / "Confirmed packets"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_012 / "RXParamSetupReq MAC command"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_013 / "RXTimingSetupReq MAC command"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_014_A / "LinkADDRReq MAC command (Part 1)"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_014_B / "LinkADDRReq MAC command (Part 2)"	DE1247001aa01	2021-02-09	PASS	
TP_A_EU868_ED_MAC_BV_015_A / "RX1 Receive windows test (Part 1)"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_015_B / "RX1 Receive windows test (Part 2)"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_016 / "RX2 Receive window test"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_017 / "RX1 and RX2 simultaneous frames"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_018 / "TXParamSetupReq MAC command"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_019 / "LinkCheckReq MAC command"	DE1247001aa01	2021-02-10	PASS	

Test Case ID	Sample	Date	Verdict	Comments
TP_A_EU868_ED_MAC_BV_020 / RX "Oversized payload"	DE1247001aa01	2021-02-10	PASS	
TP_A_EU868_ED_MAC_BV_021 / "Maximum Allowed payload"	DE1247001aa01	2021-02-10	PASS	

4 Test Equipment Details

4.1 List of Test Equipment

The information shown below is valid for the testing time frame of this test report.

Test Resource 1: LCTT LoRaWAN Compliance Test Tool

Description: for LoRaWAN Specification and LoRa Compliance Testspec

Test System LCTT LoRaWAN Compliance Test Environment of Test Resource LCTT LoRa Compliance Test Environment

Test System:	LCTT LoRaWAN Compliance Test Environment
Description:	Location: 7layers Conformance Lab
Manufacturer:	LoRa Alliance

Software Component and Version	Start Date	End Date
LCTT LoRa Compliance Test Tool User Interface v1.7		
LCTT Technology Package v3.1.0_R1	2020-12-16	

Single Devices of Test System 7layers LoRa Compliance Test Environment

Name	Serial Number	Manufacturer
7Layers LoRa Control PC	DSCM004667	Fujitsu
Semtech SX1301 LoRa 8-Channel Gateway for EU 868MHz	IOTSX1301	Semtech
	<i>Software Version</i>	<i>Start Date</i>
	Lora Gateway SW (Driver HAL) v5.0.1; Packet forwarder v4.0.1	2021-01-01
	<i>End Date</i>	
Kerlink Wirnet iBTS compact LoRa 16-Channel Gateway for EU 868MHz	703BCc030016	Kerlink
	<i>Software Version</i>	<i>Start Date</i>
	Semtech Packet Forwarder V2 v5.1.0-klk4 (June 2018); Semtech HALv2 v5.1.0-klk5 (June 2018)	2021-01-01
	<i>End Date</i>	

5 Annex

5.1 Object Under Test (OUT) Features

Supported Features for Object Under Test: PrismaSeT Wireless Panel Server

Name	Mnemonic
LoRa End Device Certification EU v1.6	
Band 868 MHz	Yes
Band US902-928	No
Band EU433	No
Band AU915-928	No
Band CN470-510	No
Band AS923	No
Band KR920-923	No
Class A Device	Yes
Class C Device	No
LoRaWAN v1.0.2rB certification requirements	Yes
DUT supports the Lorawan-1.0.x-join-synch-issues-remedies-v1.0.0	No
data rate SF7BW250 (DR6)	Yes
data rate FSK (DR7)	Yes
OTAA	Support of optional over-the-air feature
ABP	No Support of optional activation-by-personalization
ADR	Support of Adaptive Data Rate
JOIN	No Support of allow to trigger join request on port 224
DIChannelReq	Yes
Block of LinkADRReq command processing	Yes
Data Rate Decay	Yes
uplink re-transmissions for Confirmed frames	Yes
Output Power	Support 0dBm to 14dBm

5.2 Sample DE1247001aa01 Extra Information Parameters

Sample Name: DE1247001aa01	
Object Under Test:	PrismaSeT Wireless Panel Server
Description:	PrismaSeT Wireless Panel Server for Voltage Loss Alarm
Serial Number:	0080F4FFFEC8FFCF
Code:	aa01
End Device Identifier (DevEUI)	0080F4FFFEC8FFCF
Application Identifier (AppEUI)	000054FFFEC8FFCF
Application key (AppKey)	EFB28C6DD9572ABBDBCA69131C2A20A2
Maximum number of uplinks re-transmission	7
Frame counter size	32


5.3 Additional Documentation for Samples

The following documents have been attached to Sample definitions as supporting documentation.

Object Under Test: PrismaSeT Wireless Panel Server

Sample Name: DE1247001aa01

Front view:



End of Test Report